



Date of Inspection: 6/17/2025
Facility: Possum Point Pond D

Annual Inspection Report for Existing CCR Surface Impoundment

Reference: 40 CFR Section 257.83, *Inspection Requirements for CCR Surface Impoundments*

Owner Information


Name of Dam: Possum Point Ash Dam D
Owner's Name: Virginia Electric and Power Company d.b.a. Dominion Energy Virginia
State ID #: DCR Inventory #153020
Owner Contact: Robert Carr: (804) 573-5991
Dam Location: Dumfries, Virginia

Engineer Information

Name and Virginia License Number: Jeremy Frantz (067095)
Firm Name: Schnabel Engineering
Firm Address: 9800 JEB Stuart Parkway, Suite 100, Glen Allen, VA 23059
Telephone No.: 804-921-5735

Certification Statement

I certify that the inspection of the above listed CCR surface impoundment was conducted in conformance with the requirements listed in 40 CFR 257.83, and with generally accepted good engineering practices.



Engineer seal, signature and date

As used herein, the word certify shall mean an expression of the Engineer's professional opinion to the best of his or her information, knowledge and belief, and does not constitute a warranty or guarantee by the Engineer.



Date of Inspection: 6/17/2025
Facility: Possum Point Pond D

Was a review performed of available information regarding the status of the CCR unit, including files in the operating record?

Yes	No
X	

Was a visual inspection performed (i) to identify signs of stress or malfunction of the CCR unit and appurtenant structures, and (ii) of all hydraulic structures underlying the base or passing through the dike of the CCR unit for structural integrity and safe and reliable operation?

X	
---	--

Identify any changes in the geometry of the impounding structure since the previous annual inspection.

No changes were observed.

Verify the type, location, and condition of existing instrumentation (e.g. flow meter or staff gauge).
Document the maximum recorded readings of each instrument since the previous annual inspection.

Water levels are recorded using portable survey equipment on a 30-day basis. A maximum water elevation of 118.2 was recorded on 5/21/25.

Five piezometers were installed in 2023. Three piezometers (PZ-D1, PZ-D2, & PZ-D3) are installed within the embankment while two more are installed at the toe of the slope (PZ-D4 & PZ-D5). The piezometers at the toe of slope are intended to remain dry unless there is an issue with the toe drain or an upper phreatic surface develops from heavy rainfall.

Maximum elevations are as follows: PZ-D1 60.55 (8/20/24); PZ-D2 47.96 (7/23/24); PZ-D3 98.41 (1/8/25); PZ-D4 Dry; PZ-D5 Dry

List the minimum, maximum, and present depth and elevation of impounded water and CCR since the previous annual inspection.

Water level in pond:

Minimum Depth (ft)	30.2	Maximum Depth (ft)	31.2	Present Depth (ft)	31.2
Minimum Elev. (ft)	117.2	Maximum Elev. (ft)	118.2	Present Elev. (ft)	118.2

CCR level in pond:

Minimum Depth (ft)	68.0	Maximum Depth (ft)	101.0	Present Depth (ft)	Varies*
Minimum Elev. (ft)	88.0	Maximum Elev. (ft)	141.0	Present Elev. (ft)	Varies*

***CCR SURFACE TOPOGRAPHY VARIES BETWEEN MIN AND MAX ELEVATION**

Maximum Storage Capacity: 4,986 Ac - Ft.

Present volume of the impounded water:	659	Ac - Ft.
Present volume of the impounded CCR:	2,743	Ac - Ft.
Present volume, total:	3,402	Ac - Ft.



Date of Inspection: 6/17/2025
Facility: Possum Point Pond D

Identify any appearances of an actual or potential structural weakness of the CCR unit or existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit and appurtenant structures.

None observed.

Identify any changes that may have affected the stability or operation of the impounding structure since the previous annual inspection.

None observed.

Additional comments

Ash Pond D meets the definition of an existing CCR surface impoundment under 40CFR 257.53 of the "Standards for the Disposal of Coal Combustion Residuals (CCR) in Landfills and Surface Impoundments." Pond D no longer receives CCR. Engineering and site characterization work is ongoing to support the required closure by removal of CCR pursuant to §10.1-1402.03 of the Code of Virginia.