

TERMS AND CONDITIONS

---

VI. CHARACTERISTICS OF ELECTRICITY SUPPLIED

A. The Company normally provides single phase, 60 Hertz (cycle) alternating current at approximately 120/240 Volts, or three-phase, four-wire at approximately 208Y/120 Volts, and in some instances three-phase, four-wire at approximately 480Y/277 Volts. When other voltages are desired, the Company should be contacted.

B. The characteristics at which electricity will be furnished at each installation will be given in writing to the Applicant.

C. To eliminate the possibility of error or loss, the Applicant or Customer, before purchasing motors or other equipment or undertaking to install wiring, should secure from the Company in writing all necessary data relating to the characteristics of the electricity and the related connections which are supplied, or will be supplied in the future.