

TERMS AND CONDITIONS

---

XIX. TESTING FACILITIES AND EQUIPMENT

A. The Company will maintain testing facilities and metering equipment, unless specifically relieved of this obligation by the Commission, in general accordance with the provisions of the American National Standard Code for Electricity Metering, as revised from time to time.

B. A suitable laboratory shall be maintained and equipped with such standard meters, instruments and facilities in accordance with the Commission's Rules and Regulations. These are to serve as reference standards for the calibration of all types of instruments normally used in the testing of watt-hour meters in service.

C. Wattmeters, and other instruments shall be checked periodically against standards to ensure accuracy.