

**NOTIFICATION OF INTENT TO CLOSE CCR SURFACE IMPOUNDMENTS
MOUNT STORM POWER STATION**

Virginia Electric and Power Company d/b/a Dominion Virginia Power (Dominion) owns and operates the Mount Storm Power Station (Station). The Station operates five low volume waste settling ponds (LVWSP) (Pyrite Pond and Ponds A, B, C, and D), which meet the definition of coal combustion residual (CCR) surface impoundments under the United States Environmental Protection Agency (USEPA) Disposal of Coal Combustion Residuals From Electric Utilities Final Rule (CCR Rule). Dominion intends to initiate closure of Ponds A, B, C, and D under the requirements of 40 CFR 257.102 of the CCR rule. This Notification of Intent to Close CCR Surface Impoundments has been prepared pursuant to 40 CFR 257.102 (g). Ponds A, B, C and D will complete closure by removal of CCR in accordance with 40 CFR 257.102 (c), which is expected to be completed in 2018. The Pyrite Pond was previously retrofitted in accordance with 40 CFR 257.102 (k) and handled under a separate notification.

R. Kent Nilsson

Printed Name of Professional Engineer



Signature of Professional Engineer

21543

State of West Virginia License Number

February 1, 2017

Date

