

| Measures for Non-Residential Heating & Cooling Efficiency Program | | |
|--|--------------------------------------|---------------------------|
| Size Range | Minimum Qualifying Efficiency | Incentive Per Ton* |
| Packaged Terminal Air Conditioner Units and Heat Pumps | | |
| < 7k Btu/h | 11.3 EER | \$37 |
| ≥ 7k and < 15k Btu/h | 10.0 EER | \$37 |
| ≥ 15k Btu/h | 9.2 EER | \$37 |
| Unitary Air Cooled Air Conditioners | | |
| All Split Units < 60k Btu/h (5 tons) | 12.5 EER or 15.0 SEER | \$45 |
| All Single Package Units < 60k Btu/h (5 tons) | 12.0 EER or 15.0 SEER | \$45 |
| ≥ 60k and < 132k Btu/h (5 – 11 tons) | 12.0 EER | \$45 |
| ≥ 132k and < 240k Btu/h (11 – 20 tons) | 12.0 EER | \$45 |
| ≥ 240k and < 756k Btu/h (20 – 63 tons) | 10.6 EER | \$45 |
| All Units ≥ 756k Btu/h (63 tons) | 10.2 EER | \$45 |
| Unitary Air Cooled Heat Pumps | | |
| All Split Units < 60k Btu/h (5 tons) | 12.5 EER or 15.0 SEER | \$45 |
| All Single Package Units < 60k Btu/h (5 tons) | 12.0 EER or 15.0 SEER | \$45 |
| ≥ 60k and < 132k Btu/h (5 – 11 tons) | 11.1 EER | \$45 |
| ≥ 132k and < 240k Btu/h (11 – 20 tons) | 10.7 EER | \$45 |
| ≥ 240k and < 756k Btu/h (20 – 63 tons) | 10.1 EER | \$45 |
| Water Cooled Chillers | | |
| Rotary / Screw / Scroll Type < 75 tons | 0.50 kW/Ton | \$51 |
| Rotary / Screw / Scroll Type ≥ 75 and < 150 tons | 0.49 kW/Ton | \$53 |
| Rotary / Screw / Scroll Type ≥ 150 and < 300 tons | 0.44 kW/Ton | \$49 |
| Rotary / Screw / Scroll Type ≥ 300 tons | 0.41 kW/Ton | \$41 |
| Centrifugal < 150 tons | 0.44 kW/Ton | \$47 |
| Centrifugal ≥ 150 and < 300 tons | 0.40 kW/Ton | \$41 |
| Centrifugal ≥ 300 tons | 0.39 kW/Ton | \$33 |
| Magnetic Bearing < 150 tons | 0.37 kW/Ton | \$62 |
| Magnetic Bearing ≥ 150 and < 300 tons | 0.357 kW/Ton | \$52 |
| Magnetic Bearing ≥ 300 tons | 0.33 kW/Ton | \$46 |
| Air Cooled Chillers | | |
| All Sizes | 12.5 EER | \$52 |
| Geothermal Heat Pumps | | |
| All Sizes | 18.1 EER | \$42 |
| Variable Frequency Drives | | |
| For HVAC Equipment Only | | \$56/hp |
| HVAC Economizers | | |
| Dual Enthalpy Economizers < 10 tons | | \$98/unit |
| Dual Enthalpy Economizers ≥ 10 tons | | \$156/unit |

*For more information, please call 1-888-366-8280. The regulatory approval period for the Non-Residential Heating and Cooling Efficiency program is expiring. All projects must be completed with a participating contractor by December 28, 2018 with rebate applications submitted online or postmarked by February 11, 2019. Rebate amounts are subject to modifications without notice, and projects must be complete before rebates will be paid. Minimum Qualifying Efficiency Level for Water Cooled Chillers and Air Cooled Chillers represents the Partial Load Efficiency (IPLV).

| Size Range | Minimum Qualifying Efficiency | Incentive Per Ton* |
|---|---------------------------------|--------------------|
| Mini Split Air Conditioners and Heat Pumps | | |
| Level 1 ≤ 60k Btu/h | 11.8-13.7 EER or 14.0-18.0 SEER | \$60 |
| Level 2 ≤ 60k Btu/h | 13.8-14.9 EER or 18.1-21.9 SEER | \$110 |
| Level 3 ≤ 60k Btu/h | 15.0 EER or 22.0 SEER | \$150 |
| Variable Refrigerant Flows | | |
| ≥ 60k and < 132k Btu/h | 14.0 EER or 14.2 IEER | \$80 |
| ≥ 132k and < 240k Btu/h | 13.0 EER or 13.7 IEER | \$70 |
| ≥ 240k Btu/h | 12.4 EER or 13.0 IEER | \$60 |
| Water Source Heat Pumps and Air Conditioners | | |
| ≤ 132k Btu/h | 14.0 EER | \$80 |

*For more information, please call 1-888-366-8280. The regulatory approval period for the Non-Residential Heating and Cooling Efficiency program is expiring. All projects must be completed with a participating contractor by December 28, 2018 with rebate applications submitted online or postmarked by February 11, 2019. Rebate amounts are subject to modifications without notice, and projects must be complete before rebates will be paid. Minimum Qualifying Efficiency Level for Water Cooled Chillers and Air Cooled Chillers represents the Partial Load Efficiency (IPLV).